

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0900:112

Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fike Protection Systems, 704 S. 10th St., Blue Springs MO 64105
Contact: *Sean Titus (816) 229-3405 ext 281 FAX (816) 229-5082

DESIGN: Model Rhino fire alarm control unit. Power-limited; local, automatic, manual, coded, noncoded, sprinkler supervisory and releasing device service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

10-050-1-R/-G	Enclosure
10-050-2-R/-G	Enclosure
10-2141, -2144 (DCM)	Detection and Control Module
10-2142 (IDM)	Interactive Display Module
10-2143 (RM4)	Relay Module
10-1832 (ARM-III)	Agent Release Module

RATING: Input: 120/240 VAC; Standby: 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**